



Province of
British Columbia

Ministry of
Environment
and Parks
ENVIRONMENT DIVISION

3547 Skaha Lake Road
Penticton
British Columbia
V2A 7K2
Telephone: (604) 493-8261

March 14, 1988

Our File: 77.1101 - RDCO (1294)

Your File: DP 88-327

Regional District of
Central Okanagan
540 Groves Avenue
Kelowna, B.C.
V1Y 4Y7

Dear Sir:

Re: Application for development Variance Permit
Wm R. & Anne M. Hicks - Lot 1, Plan 8596, D.L. 2186

The Ministry of Environment and Parks has the applicants proposal to construct a boathouse 4.6 metres (15 feet) from the natural boundary of Okanagan Lake.

The Ministry of Environment and Parks has no objection to a relaxation of the setback requirements (from 7.5 m to 4.6 m) provided that no area is used for habitation or storage of goods damageable by floodwaters at an elevation of less than 343.66 metre G.S.C. datum. (approximately five feet above the natural boundary). The Regional District of Central Okanagan, however, may choose not to grant a relaxation for this proposal.

Yours truly,

A.D. Zackodnik, P. Eng.
Regional Manager
Water Management Program
Southern Interior Region

ALCOCK/pa

